


KLEE


Klee series installation instructions

SERIES	L (mm)	L1 (mm)	Cutout (mm)	Cutout when splicing (mm)
LR00102	511	500	507 × 35	(n × 500 + 7) × 35
	1011	1000	1007 × 35	(n × 1000 + 7) × 35
	1211	1200	1207 × 35	(n × 1200 + 7) × 35
	1511	1500	1507 × 35	(n × 1500 + 7) × 35




Installation Steps:


01 Cut a hole in the ceiling corresponding to the length of the luminaire, and lead out power cords.




02 Connect the light and driver (make sure that the driver is consistent with the current parameters on the lamp), and the driver line with mains supply.



03 Put the driver into the ceiling



04 Break off the shrapnel, insert one shrapnel first, and then insert the other, the installation is complete




1.

2.


3.

Method for Splicing:



The actual appearance shall prevail in kind!

4.



This product is only suitable for indoor, it is not allowed to be rinsed with water.

Independent external driver, recessed mounted.

5.

Do not clean LED chip and reflector with hand or towel !



- Use only drivers that comply with IEC or CE safety standards.
- Check if the power supply match with the luminaire.
- Must consider the maximum current value displayed on the label of the luminaire.
- The voltage displayed on the luminaire is not used to select the constant voltage driver, but the voltage covered by the selected constant current driver.
- Take suitable ESD measures to avoid touching bare conductors.
- LED chips can be damaged if be in touch with chemical material or gas. Therefore, it is not allowed to clean the LED housing or luminaire by chemicals.
- The following items are confirmed to have negative impact on the performance of the luminaire, avoid to keep luminaire in the same circumstance with them.
 - Methyl acetate or ethyl acetate (i.e., nail polish remover)
 - Cyanoacrylates (i.e., "Superglue")
 - Glycol ethers (including Radio Shack ® Precision Electronics Cleaner - dipropylene glycol monomethyl ether)
 - Formaldehyde or butadiene (including Ashland PLIOBOND ® adhesive)
 - Dymax 984-LVUF conformal coating
 - Loctite Sumo Glue, Loctite 384 adhesive, Loctite 7387 activator
 - Gorilla Glue, Bleach, Bleach-containing cleaners, sprays
- Remove the insulation material from the luminaire or provide enough space so that the temperature raising will not overpass the limited TC.
- LED chip is very sensitive to switching transients, therefore, LED lamps and appliances must be connected after power cut off, no hotswappable.
- Recommends using the driver indicated on the luminaire manual.
- Must consider the polarity of the product.
- If the external flexible cable or cord of this lamp is damaged, the cord should be replaced by the manufacturer or its service agent or a similarly qualified person
- The light source in this lamp should be replaced by the manufacturer or its service agent or a similarly qualified person

6.