



Mizar70 recessed series installation instructions

Series	Cut Out
LR00210	L1004XW61*H62 (height > 62mm)
LR00211	L1004XW61*H62 (height > 62mm)


1 The dimension of fitting





2. Installation Steps (This picture only supplies the reference, please take the actual product as the standard)





2.














- Use only drivers that comply with IEC or CE safety standards.
- Check if the power supply match with the luminaire.
- Must consider the maximum current value displayed on the label of the luminaire.
- The voltage displayed on the luminaire is not used to select the constant voltage driver, but the voltage covered by the selected constant current driver.
- Take suitable ESD measures to avoid touching bare conductors.
- LED chips can be damaged if be in touch with chemical material or gas. Therefore, it is not allowed to clean the LED housing or luminaire by chemicals.
- The following items are confirmed to have negative impact on the performance of the luminaire, avoid to keep luminaire in the same circumstance with them.

Methyl acetate or ethyl acetate (i.e., nail polish remover)

Cyanoacrylates (i.e., "Superglue")

Glycol ethers (including Radio Shack ® Precision Electronics

Cleaner - dipropylene glycol monomethyl ether)

Formaldehyde or butadiene (including Ashland PLIOBOND ® adhesive)

Dymax 984-LVUF conformal coating

Loctite Sumo Glue Loctite 384 adhesive Loctite 7387 activator

Gorilla Glue Bleach, Bleach-containing cleaners, sprays

- Remove the insulation material from the luminaire or provide enough space so that the temperature raising will not overpass the limited TC.
- LED chip is very sensitive to switching transients, therefore, LED lamps and appliances must be connected after power cut off, no hotswappable.
- Recommends using the driver indicated on the luminaire manual.
- Must consider the polarity of the product.
- It is recommended to use an ambient temperature of -10 ° C to 40 ° C for indoor lighting
- If the external flexible cable or cord of this lamp is damaged, the cord should be replaced by the manufacturer or its service agent or a similarly qualified person
- The light source in this lamp should be replaced by the manufacturer or its service agent or a similarly qualified person